



NOTES:

1. MINIMUM GRADE FOR 100mm SEWER PIPE IS 2.00%.
MINIMUM GRADE FOR 150mm SEWER PIPE IS 1.00%.
2. ON PRE-SERVICED CONNECTIONS, END OF SEWER TO HAVE END PLUG INSTALLED AND WATER LINES SEALED WITH P.V.C. TAPE.
3. WHEN FACING BUILDING – SERVICES:
 LEFT CENTRE RIGHT
 STORM SANITARY WATER

			CITY OF PRINCE ALBERT		APPROVED
			PUBLIC WORKS		<i>Wes Hicks</i>
			TYPICAL SEWER AND WATER CONNECTION		SCALE N.T.S.
No.	DATE	REVISION	DRAWN S. NUMEDAHL	DESIGNED N. MILLER	DWG. No. 00-01-10
			DATE OCT. 2014		