



## City of Prince Albert Drinking Water Quality and Compliance

The Water Security Agency and Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a Waterworks. The following is a summary of the City of Prince Albert's water quality and sample submission compliance record from January 1, 2021 to December 31, 2021. This report was completed on February 3, 2022. Readers should refer to the Saskatchewan Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

### Water Quality Standards

#### Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (Percentage)
Total Coliform	0 organisms/100 mL	572	570	0 samples tested positive for total coliforms = 99.6 % compliance.
E. coli	0 organisms/100 ml			
Background Bacteria	Less than 200 organisms/100 mL			

*The owner/operator is responsible to ensure that one hundred percent of all bacteriological samples are submitted as required. Generally, analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks. The City of Prince Albert is required to submit eleven (11) bacteriological samples per week for analysis.*

#### Water Disinfection – Chlorine Residual for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (mg/L)	Free Chlorine Residual Range	Total Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual in Distribution System	0.1 mg/L free OR 0.5 mg/L total	0.10 mg/l to 1.95 mg/l	0.40 mg/l to 2.03 mg/l	572	570	(100%)

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system unless otherwise approved. A proper chlorine submission is defined as a bacteriological sample submission form with both the free and total chlorine residual fields filled out. Adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. Adequate chlorine may be counted even if the chlorine results were submitted incorrectly. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.*

**Water Disinfection – Free Chlorine Residual of the water leaving the River Street Reservoir – From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	0.10	0.66 mg/l to 1.80 mg/l	Continuous on line monitoring	0

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water leaving the River Street Reservoir before the next chlorine injection point. Potable water is monitored continuously for free chlorine residual and tests are normally performed on a daily basis by the waterworks operators and are recorded into the operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.*

**Turbidity**

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required
Filter A Turbidity	1.0	0.014 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter B Turbidity	1.0	0.012 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter C Turbidity	1.0	0.020 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter D Turbidity	1.0	0.002 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter E Turbidity	1.0	0.008 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter F Turbidity	1.0	0.010 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter G Turbidity	1.0	0.010 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Filter H Turbidity	1.0	0.010 - 0.30	0	0.30	Continuous Monitoring & grab sample comparisons
Water entering the Distribution	5.0	0.06 – 0.97	0	0.97	Continuous Monitoring & grab sample comparisons

*Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU). All waterworks are required to monitor turbidity at the water treatment plant. The frequency of measurement varies from daily for small systems to continuous for larger waterworks. The City of Prince Albert is required to continuously monitor the filter effluent from each filter.*

**“<” means less than**

<b>Chemical – Health Category</b>			<b>Feb 2, 2021</b>	<b>May 4, 2021</b>	<b>July 13, 2021</b>	<b>Nov 18, 2021</b>		<b># Samples</b>	<b># Samples</b>
<b>Parameter</b>	<b>Limit MAC (mg/L)</b>	<b>Limit IMAC (mg/L)</b>	<b>Sample Results (mg/l)</b>	<b>Sample Results (mg/l)</b>	<b>Sample Results (mg/l)</b>	<b>Sample Results (mg/l)</b>	<b>Samples Exceeding MAC/IMAC</b>	<b>Required</b>	<b>Submitted</b>
Aluminum			0.029	0.0390	0.0988	0.0214	0	2 per year	4
Antimony	0.006		<0.00010	0.00011	0.00023	<0.00010	0	2 per year	4
Arsenic	0.010		0.00011	0.00017	0.00019	0.00013	0	2 per year	4
Barium	2.0		0.0609	0.0516	0.0563	0.0491	0	2 per year	4
Beryllium	no current standard		<0.00020	<0.00020	<0.00020	<0.00020	0	0 per year	4
Boron		5.0	0.026	0.032	0.028	0.022	0	2 per year	4
Cadmium	0.007		0.0000102	0.0000080	0.0000064	0.000062	0	2 per year	4
Chromium	0.05		<0.00050	<0.00050	<0.00050	<0.00050	0	2 per year	4
Cobalt	no current standard		<0.00010	<0.00010	<0.00010	<0.00010	0	0 per year	4
Copper	2 mg/l		0.00132	0.00172	0.00140	0.00107	0	2 per year	4
Fluoride (avg.*)	1.5 mg/l		Max result 1.02 mg/l; Average for Year 0.60 mg/l				0	417	768
Iron	Aesthetic objective	0.3 mg/l	<0.010	<0.010	<0.010	<0.010	0	2 per year	4
Lead	0.005		<0.000050	<0.000050	<0.000050	<0.000050	0	2 per year	4
Manganese	0.05 mg/l		0.00246	0.00156	0.00422	0.00522	0	2 per year	4
Molybdenum	no current standard		0.00979	0.00103	0.00114	0.00104	0	0 per year	4
Nickel	no current standard		0.00076	0.00080	0.00084	0.00081	0	0 per year	4
Nitrate-N	10		0.575	<0.020	<0.020	0.380	0	0 per year	4
Nitrite-N	1.0		<0.010	<0.010	<0.010	<0.010	0	0 per year	4
Selenium	0.05		0.000190	0.000232	0.000297	0.000194	0	2 per year	4
Silver	no current standard		<0.000010	<0.000010	<0.000010	<0.000010	0	2 per year	4
Thallium	no current standard		<0.000010	<0.000010	<0.000010	<0.000010	0	0 per year	4
Uranium	0.02		0.000399	0.000153	0.000071	0.000160	0	2 per year	4
Zinc	Aesthetic objective	5 mg/l	<0.0030	<0.0030	<0.0030	<0.0030	0	2 per year	4

Substances within the chemical health category may be naturally occurring in drinking water sources or may be the result of human activities. These substances may represent a long-term health risk if the Maximum Acceptable Concentration (MAC) or Interim Maximum Acceptable Concentration (IMAC) is exceeded. All drinking water supplies are required to monitor for substances in the “Chemical-Health” category, the frequency of monitoring depends on the population served by the waterworks. Some waterworks add fluoride to drinking water as a means to aid in the prevention of dental decay.

\* Results expressed as average values for communities or waterworks which fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.

### **Chemical – Cyanide and Mercury**

<b>Parameter</b>	<b>Limit MAC (mg/L)</b>	<b>May 4, 2021 Sample Results</b>	<b>October 14, 2021 Sample Results</b>	<b># Samples Exceeding MAC</b>	<b># Samples Required</b>	<b># Samples Submitted</b>
Cyanide	0.2	<0.005	<0.005	0	2 per year	2
Mercury	0.001	<0.000005	<0.000005	0	2 per year	2

**“<” means less than**

Mercury enters water supplies naturally and as a result of human activities. Cyanide can enter source waters as a result of industrial effluent or spill events. These substances may represent a long-term health risk if the Maximum Acceptable Concentration (MAC) is exceeded. Mandatory sampling requirements depend on the population served by the waterworks.

**Chemical – Trihalomethanes & Haloacetic Acids** – Samples submitted February 2, April 12, August 18 & December 8, 2021

Parameter	Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.100	0.031	8 (two every 3 months)	8
Haloacetic Acids	0.080	0.019	8 (two every 3 months)	8

*Trihalomethanes and Haloacetic Acids are generated during the water disinfection process, a by-product of reactions between chlorine and organic material. Trihalomethanes are generally found only in drinking water obtained from surface water supplies. Trihalomethanes and Haloacetic Acids are to be monitored on a quarterly basis and the Maximum Acceptable Concentration is expressed as an average of 4 quarterly samples. Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor Trihalomethane and Haloacetic Acids unless otherwise specified in the waterworks permit to operate.*

“<” means less than

**General Chemical**

(February 2, May 4, July 13, November 18, 2021)

Parameter	Aesthetic Objectives* (mg/L)	Sample Results (average mg/l)	# Samples Required	# Samples Submitted
T – Alkalinity (as CaCO <sub>3</sub> )	500	134	4 per year	4
Bicarbonate	No Objective	164	4 per year	4
Dissolved Calcium	No Objective	48.9	4 per year	4
Carbonate	No Objective	<1.0	4 per year	4
Chloride	250	22.4	4 per year	4
Conductivity	No Objective	458 uS/cm	4 per year	4
Hardness mg CaCO <sub>3</sub> /L	800	195	4 per year	4
Dissolved Magnesium	200	17.6	4 per year	4
Dissolved Potassium	No Objective	2.4	Supplementary Sampling	4
PH	No Objective	7.75	4 per year	4
Dissolved Sodium	300	17.3	4 per year	4
Sulphate	500	68.9	4 per year	4
Total dissolved solids	1500	262	4 per year	4

All waterworks serving more than 5000 persons are required to submit water samples for the General Chemical category as per their permit to operate. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids. The last sets of quarterly samples for General Chemical analysis were required to be submitted (Jan-March, April-June, July-September, October-December of 2021). Sample results indicated that there were no exceedances of the provincial aesthetic objectives for the General Chemical category.

*\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality*

**Cryptosporidium & Giardia – For Raw Untreated River Water**

Yearly Sampling requirements depend on permit specific requirements. The Raw river water sampling outlined in the City of Prince Alberts Permit to Operate a Waterworks, was conducted April 26 & October 14, 2021.

**Microcystin-LR and/or Total Microcystin Toxins**

Parameter	Limit MAC (mg/l)	June 2 Sample Results	July 13 Sample Results	August 4 Sample Results	September 28 Sample Results	October 14 Sample Results	# Samples Exceeding Limit	# Samples Required	# Samples Submitted
Microcystin	0.0015	<0.00020	<0.00020	<0.00020	<0.00020	<0.00020	0	(variable)	5

**“<” means less than**

Sampling requirements depend on permit specific requirements.

**Radiological**

Parameter	Limit Becquerels/L	August 4, 2021 Sample Results	# Samples Exceeding Limit	# Samples Required	# Samples Submitted
Gross Alpha	0.50	<0.19	0	1 per year	1
Gross Beta	1.0	<0.10	0	1 per year	1

**“<” means less than**

Radiological constituents in drinking water may be the result of natural conditions or as a result of human activities. Gross alpha and Gross Beta are initial water quality screening tests used to determine the overall quality of drinking water for a larger set of specific radiological parameters. Further sampling may be required if Gross Alpha or Beta exceedences are found. Sampling requirements depend on permit specific requirements.

**More information on water quality and sample submission performance may be obtained from:**

City of Prince Albert  
 Andy Busse, Water Treatment Plant Manager  
 1084 Central Avenue  
 Prince Albert, SK. S6V 7P3  
 Phone: 306-953-4900